


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 09146 / 01.12.2009**

| | | | |
|---------------|--------------|-------------|-----------------------|
| NUMBER | 09146 | DATE | 01 / 12 / 2009 |
|---------------|--------------|-------------|-----------------------|

| | |
|-----------------------------|---|
| Client' s data: | ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE |
| Product description: | SINGLE SASH WINDOW WITH ONE FIXED ELEMENT TILT / TURN |
| Material: | ALUMINIUM |
| System : | E - 1000 |



1410 x 2210mm

| | |
|--|-----------------|
| Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i> | Class 3 |
| Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i> | Class 7A |
| Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i> | Class C2 |

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPAPOPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL