


SUMMARY OF RESULTS OF TESTING CERTIFICATE 0537 / 04.07.2005

NUMBER	0537	DATE	04 / 07 / 2005
---------------	------	-------------	----------------


Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIUO STR. GR 190 18 MAGOULA ATTIKIS - GREECE
Product description:	DOUBLE SASH WINDOW SLIDING
Material:	ALUMINIUM
System :	E - 19



1310 x 1310 mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 4A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C4

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPAPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL