



IRCCOS S.c.a r.l.

Istituto di Ricerca e certificazione per le Costruzioni Sostenibili

Test Laboratory Notified in accordance with Regulation (EU) No 305/2011

TEST REPORT

Number:

1994-CPR-RP1025

Issuing date:

2014-03-20

Applicant:

Etem SA

**Iroon Polytechniou str, 1
1908 – Magoula, Attiki (Greece)**

Tested product:

Single vent pocket sliding door

Trade name: "E-50"

(cf. description)

Executed tests:

Air permeability

Watertightness

Resistance to wind load

Normative References:

EN 14351-1:2006+A1:2010

EN 1026:2000 EN 12207:1999

EN 1027:2000 EN 12208:1999


EN 12211:2000 EN 12210:1999

The report is done up of 27 pages, including any annex, and can be reproduced only integrally.

*Sede legale Via Cremona 1 - 20025 Legnano (MI) - Tel. 0331 594628 - Fax 0331 458211 - www.irccos.com
Cap. Soc. € 111.526 I.V. - C.F. e P. Iva 05159630960 - Reg. Imprese Milano 05159630960 - R.E.A. 1799766*

Società partecipata a maggioranza dal Consiglio Nazionale delle Ricerche

- 9 Resume of classes assigned on the basis of the results of the tested sample of a Single vent pocket sliding door with trade name “E-50”, according to TR n° 1994-CPR-RP1025, issued on 2014-03-20 to ETEM SA.


Scheme of the tested sample	Test	Test standard	Classification standard	Obtained Class	Cf. § TR
 <p>2305(H) x 2000(W) mm</p>	Air permeability	EN 1026:2000	EN 12207:1999	class 4	§ 7.2.1
	Watertightness	EN 1027:2000	EN 12208:1999	class E1200	§ 7.3.1
	Resistance to wind load	EN 12211:2000	EN 12210:1999	class C3	§ 7.4.5

10 Limitations

This Test Report does not represent either an evaluation the suitability of use or a certificate of product conformity. The results obtained refer exclusively to the samples tested.

Technical Operator

Katia Foti



The chairman

for Dott. Italo Meroni



-----End of the Test Report No. 1994-CPR-RP1025-----