


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 09180 / 21.12.2009**

| | | | |
|---------------|--------------|-------------|-----------------------|
| NUMBER | 09180 | DATE | 21 / 12 / 2009 |
|---------------|--------------|-------------|-----------------------|

| | |
|-----------------------------|---|
| Client' s data: | ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE |
| Product description: | SINGLE SASH WINDOW PIVOT |
| Material: | ALUMINIUM |
| System : | E – 45 Thermo |



| | |
|--|--------------------|
| Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i> | Class 4 |
| Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i> | Class E1050 |
| Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i> | Class C3 |

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPAPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL