


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 1024 / 18.03.2010**

NUMBER	1024	DATE	18 / 03 / 2010
---------------	-------------	-------------	-----------------------

Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE
Product description:	SINGLE SASH WINDOW WITH ONE FIXED ELEMENT TILT / TURN
Material:	ALUMINIUM
System :	E – 45 Thermo Concealed Window



1040 x 2310mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class E1050
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C5

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPAPOPOULOU
TECHNICAL MANAGER**



**IOANNIS GKERTSOS
GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL